



Fair Trading

File Ref: NSW24570/1
Contact: Admin Clerk
Telephone: 02 9895 0722
Fax: 02 9895 9917

Mr Ian Richardson
ABB Australia Pty Ltd
601 Blackburn Rd
NOTTING HILL VIC 3168

Dear Sir/Madam

RENEWAL OF CERTIFICATE OF APPROVAL: NSW24570


Residual Current Device

Please find enclosed an addendum to the certificate as sought in your application.

THE APPROVAL NOW EXPIRES ON 24/02/2020 unless it is renewed, extended, suspended or cancelled.

Any sample/s held by this Office should be collected within fifteen (15) days of this letter or the sample/s will be destroyed.

Yours faithfully,


For Commissioner for Fair Trading 10 February 2015



Fair
Trading

Ref: NSW24570/1

RENEWAL OF CERTIFICATE OF APPROVAL: NSW24570

Particulars of Renewal

The approval of Residual Current Device DS200 Series has been renewed for a period of FIVE years.

The Approval expires on ~~24/02/2020~~ unless it is renewed, extended, suspended or cancelled.


For Commissioner for Fair Trading



Certificate of Approval

ISSUED PURSUANT TO THE ELECTRICITY (CONSUMER SAFETY) ACT 2004

ISSUED TO: ABB Australia Pty Ltd

CLASS OF ARTICLE: Residual Current Device

DESCRIPTION OF ARTICLE:

DIN-RAIL mounting residual current operated circuit breakers with integral overcurrent protection and being independent of line voltage (RCBO's), units referenced as Type AP-R have a high level of radio frequency immunity.

DS 201 BS C: 1P+N, 6kA, C curve, Type AC & A, 30mA, 6 - 40A.

DS201L: 1P+N, 4.5kA, C curve, Type AC & A, 10, 30, 300mA, 6 - 32A.

DS201: 1P+N, 6kA, B&C curve, Type AC & A, 10, 30, 100, 300mA, 2 - 40A.

DS201M: 1P+N, 10kA, B&C curve, Type AC & A, 10, 30, 100, 300mA, 4 - 40A.

DS202: 2P, 6kA, B&C curve, Type A, 30, 300mA, 6 - 32A.

DS202 M: 2P, 10kA, B&C curve, Type A, 10, 30, 300mA, 6 - 32A.

Trade Name or Mark: ABB

Volts: 230

Amperes:

Watts:

Hertz: 50 Hz

Other Name Plate Particulars:

EXAMINED FOR COMPLIANCE WITH: AS/NZS 61009.1 : 2004, A1

TYPE REFERENCE CODE: DS200 Series

APPROVAL MARK:

Each electrical article of the type described above shall be marked with Approval Number NSW24570;

or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

DATE OF APPROVAL: 24/02/2010

This approval expires 24/02/2015 unless suspended, cancelled, renewed or extended.

for Commissioner for Fair Trading